



ITS LABORATORY

(An ISO 9001: 2015 Certified Laboratory)

Laboratory: A-91, Sector 80, Phase-2, Noida, Gautam Budh Nagar-201301, (U.P.)

M.: 09911659800, 09971305475, 07210888634

TEST REPORT

Chemical Analysis

Report Code: MS-060120 -02

Issue Date: 10/04/2022

Issued To :

DOKSHAM POWER SOLUTIONS

H51A, Road No 2-D, Bindayka Ind. Area, Bindayka,
Jaipur- 302041

PART A: Particulars of Sample submitted

A.	Sample Description	:	BACK FILL COMPOUND
B.	Name of Test	:	Resistivity, pH
C.	Quantity	:	250 gm Approx
D.	Date of Sample Received	:	06/04/2022
E.	IO's Signature	:	Signed
F.	Date of Commencement of Testing	:	06/04/2022
G.	Date of completion of Testing	:	10/04/2022

TEST RESULT


S. No.	Test	RESULT	METHOD FOLLOWED
1.	Determination of Resistivity (Ω -mtr) Before Compression After Compression	0.134 0.0752	IEC 62561-7:2011/ASTM G57-06
2.	pH	7.12	5% Solution of Distilled Water solvent
3.	Moisture Holding Capacity at 105 ⁰ C for 3 hrs, %	>10	ITS/LAB/SOP
4.	Solubility in water	0.94	ITS/LAB/SOP



Notes:

1. The results given above are related to the tested sample, as received & mentioned Parameters.
2. Responsibility of the Laboratory is limited to the invoiced amount only.
3. This test report will not be generated again, either wholly or in part, without prior written Permission of the laboratory


Checked by


Authorized Signatory